

liquid water treatments

Since 1927, Arrow-Magnolia has helped people solve their cleaning and maintenance problems with the finest products available today.

ARROW-MAGNOLIA
INTERNATIONAL, INC



SINCE 1927

GRAPE APE

LIQUID DESCRIPTION:

GRAPE APE was developed to act both as a cleaner/degreaser and a deodorizer in lift stations and wet wells.

In addition to the fresh grape scent, it contains special elements designed to remove sewage, oils, greases and soaps from the walls of lift stations.

The 2-4 inch application provides a sealing layer to eliminate odor issues as well as cleaning the walls of the system as the liquid level rises and falls.

DIRECTIONS:

-Apply 2-4 inches of GRAPE APE depending on the level of odor coverage and frequency of re-application desired.

-To determine the proper amount of product to use, multiply the square footage of the lift station or wet well by .75. This gives you the proper amount of GRAPE APE to apply per inch of coverage desired.

-Example: if 2 inches of coverage is desired in a 10'x10' lift station, then 150 gallons of GRAPE APE should be used:
(10 x 10 = 100 * .75 = 75 * 2 = 150 gallons).

manufactured by:

ARROW - MAGNOLIA INTERNATIONAL, Inc.
2646 Rodney Lane
Dallas, Texas 75229
Toll Free: 800.527.2101
www.arrowmagnolia.com

HIGHLIGHTS

- Lift Station Maintainer
- Dual Deodorizer/Degreaser
- Strong Cleaning Properties
- Fresh Grape Scent
- Also Good Asphalt/Grease Remover

TYPICAL PROPERTIES

- Vapor Pressure: **2.60**
- Volatility: **100**
- Solubility: **Insoluble**
- Specific Gravity: **0.8693**
- Vapor Density: **Heavier than**

Air

- pH: **N/A**
- Evaporation Rate: **N/A**
- Physical Description: **Clear**

Purple Liquid w/ Pleasant

Odor

SAFETY CAUTIONS

- Keep out of reach of children.
- Use non-sparking utensils when handling this material.
- Avoid hot metal surfaces.
- Use under correct atmospheric conditions in well ventilated areas.
- Keep away from excessive heat and open flames.
- Refer to SDS for additional safety information.



HMIS RATINGS

